



**Note:**

1. The machine should be located indoor, and ensure ventilation room surrounding;
2. Just before the electrical box, there should be at least 1 meter operation room.
3. The sea water circulation pump for the condenser should be prepared by the customer on site.
4. About 30 minutes after starting up, ice crystal rate 40% ice would be produced continuously.
5. At least 1 meter service room surrounding the equipment. The foundation for the equipment should be prepared by the customer previously.
6. All water and refrigeration pipelines, and electrical cables should be connected to RECOM designated ports by the customer on site.
7. Unless special instruction, it shall follow RECOM standard equipment regulation.
8. This drawing is for your reference only, which is subject to the Sales Contract.

**Technical data**

water-in temperature	20°C
ambient temperature	33°C
wet bulb temperature	25°C
ice making capacity	5t/24hr(40% ice)
power supply	3P/220V/60HZ
refrigerant	R404A
installation power	about 5.5kW
water consumption	210L/h
outside dimension	1420×1150×1250mm
running weight	about 1000kg

Itemref	Quantity	Title/Name, designation, material, dimension etc			Article No./Reference	
Designed by	Checked by	Approved by - date	Filename	Date	Scale	
			5T/day slurry ice machine layout			
			SL50W	Edition	Sheet	