



Note:

1. the evaporative condenser should be located outdoor and should be better, within 5 meters, from the ice making unit.
2. the evaporative condenser (bottom) should be at least 1 meter higher than the ice making unit (top).
3. The above dimensions are for your reference only, and at least 1 meter service room should be prepared surrounding the equipments.
4. Except the evaporative condenser, the equipments should be located indoor.
5. All water pipelines and cables should be connected. Recom designated ports by the customer.
6. All the checking platform, ladders and equipment foundation is EXcluded from the quotation. The customer should prepare according to the actual situation on site. The evaporator does not have insulation. When peeling ice, there would be condensing water falling. Please prepare for the water drain.
7. Unless special instruction, the actual design will follow our standard regulation.
8. Detailed supply scope is subject to the Sales Contract.

working conditions

ambient temperature	33°C
wet bulb temperature	25°C
water in temperature	20°C
power supply	440V/3P/60Hz
refrigerant	R404a
tube ice diameter	29mm
tube ice machine running weight	about 13T
total installation power	178.4kW

Itemref	Quantity	Title/Name, designation, material, dimension etc			Article No./Reference	
Designed by	Checked by	Approved by - date	Filename	Date	Scale	
Recom ICE SYSTEMS				50T/day Tube Ice Machine		
				TU500		Edition Sheet 1/?